



FIRST FLOOR POWER PLAN - NEW WORK
SCALE: 1/4" = 1 FOOT



02 - SHUNT TRIP BREAKER DIAGRAM
SCALE: NONE



01 - TYPICAL ACCESS CONTROL DIAGRAM
SCALE: NONE

ELECTRICAL DRAWING NOTES

GENERAL NOTE: COORDINATE ALL POWER DISTRIBUTION WITH SITE-SPECIFIC CT SCAN UNIT / VENDOR DRAWINGS AND REQUIREMENTS.

1. MOUNT ABOVE CASEWORK LEVEL.
2. OVERHEAD POWER CONNECTION - MOUNT JUNCTION BOX ABOVE CEILING, SECURED TO STRUCTURE. PROVIDE TOGGLE-SWITCH DISCONNECT AT EACH JUNCTION BOX.
3. 4" CONDUIT BANK IN SLAB. SEE CT SCAN SUITE SITE SPECIFIC DRAWINGS FOR ADDITIONAL INFORMATION.
4. PROVIDE 2" CONDUIT FROM CONTROL ROOM JUNCTION BOX TO CT SCAN EQUIPMENT CONNECTION. PROVIDE A 2" GROMMETED OPENING IN COVER OF CONDUIT FOR INJECTOR IN SCAN ROOM AND AT CONTROL DESK.
5. PUSHBUTTON FOR SHUNT-TRIP BREAKER OPERATION.
6. PROVIDE CONDUIT AT CONTROL DESK. RUN WALL CONDUIT GROUP UP WALL AND PROVIDE THREE (3) 3" CONDUITS BACK TO EQUIPMENT ROOM.
7. CONNECT VRF FAN COIL UNIT TO CIRCUIT N-15.
8. CONNECT VRF FAN COIL UNIT TO CIRCUIT N-11.
9. CONNECT VRF FAN COIL UNIT TO CIRCUIT EQP-5.
10. POWER CONNECTION FOR CT SCAN UNIT. CONNECT CIRCUIT TO UPS SYSTEM IN CT EQUIPMENT ROOM.
11. TO SYSTEM EMERGENCY OFF (SEO).
12. "A1" PRIMARY POWER DISCONNECT. 3 POLE, 380-480 V COMBINATION BREAKER WITH MAGNETIC CONTACTOR, INCLUDE OPTIONAL UPS INTERFACE.
13. CEILING MOUNTED RECEPTACLE FOR PATIENT LIFT ASSEMBLY. COORDINATE WITH EQUIPMENT.
14. PROVIDE AND MOUNT DISCONNECTS FOR FAN COIL UNITS ABOVE CEILING, ADJACENT TO FAN COIL UNIT.
15. POWER CONNECTION TO AUTOMATIC DOOR OPERATOR. COORDINATE WITH SHEET ES 4.0.
16. POWER FOR ACCESS CONTROL AND ELECTRIC DOOR LATCHES (120V). CONNECT TO CIRCUIT LS-2. SEE DETAIL 01 THIS SHEET.
17. POWER FOR ACCESS CONTROL AND ELECTRIC DOOR LATCHES (120V). CONNECT TO CIRCUIT LS-4. SEE DETAIL 01 THIS SHEET.
18. POWER CONNECTION FOR INTERCOM SYSTEM (120V).
19. 250 A, 3-POLE SHUNT TRIP CIRCUIT BREAKER FOR CT SCAN UNIT. OPERATED BY ELECTRONIC PUSHBUTTON OPERATOR (EPO) IN CT SCAN CONTROL ROOM. RUN FIVE (5) 250 KCMIL CONDUCTORS WITH #4 GROUND WIRE IN 4" CONDUIT BACK TO CT SCAN BREAKER IN SWITCHBOARD NDB. SEE DETAIL 02 THIS SHEET.
20. SEE SITE SPECIFIC VENDOR DRAWINGS FOR CONDUIT RUNS, ADDITIONAL DEVICES, REQUIREMENTS, ETC. IN THIS SPACE.
21. PROVIDE TWO (2) RELAYS AND SWITCH FOR FAN. RELAYS SHALL BE 120V AC, COIL, RATED AT 1HP, 120V CONTACT CONTROLLED BY CT SCAN UNIT. ONE RELAY IS FOR CT SCAN EQUIPMENT TO ENERGIZE FAN, SECOND RELAY IS FOR MANUAL FAN CONTROL. CONTROL FURNISHED BY EQUIPMENT VENDOR. PROVIDE CONDUIT TO OXYGEN SENSOR AND SWITCH TO RELAY, RUN THROUGH FILTER PANEL. COORDINATE LOCATION IN-FIELD.
22. PROVIDE CONNECTION FOR VRF SYSTEM BRANCH SELECTOR CONTROLLER FROM LOAD-SIDE OF DISCONNECT SWITCH OF NEAREST VRF FAN COIL UNIT.
23. NEW 225 KVA TRANSFORMER FOR UPS UNIT
24. NEW 480V, 3-PHASE, 160 KVA UPS SYSTEM INSTALLED HERE. GROUNDED FOUR-WIRE WYE CONFIGURATION. PROVIDE DEDICATED 1/0 COPPER GROUND WIRE FROM MAIN DIST. PANEL. SEE SITE SPECIFIC DRAWINGS FOR ADDITIONAL INFORMATION. SUPPLIED FROM EDP2, ROOM EC-119, BLDG. 330.
25. PROVIDE ROOF-MOUNTED DISCONNECTS AND JUNCTION BOXES AS DESCRIBED ON SHEET MH 2.0. COORDINATE WITH MECHANICAL CONTRACTOR.

EQUIPMENT STARTERS AND DISCONNECTS

EQUIPMENT DESIGNATION	EQUIPMENT SERVED	HP (KVA)	NOTES	VOLTAGE				STARTER	DISCONNECT MEANS	CONTROL	FEEDER SIZE
				120V-1PH	208V-3PH	240V-3PH	480V-3PH				
CP-1	CONDENSATE RETURN PUMP	1/2	-	•				•	EC	•	HC 2 - #12, 1 - #12 GRD, 3/4" C
EW-1	ELEC WALL HEATER	12.5 A	-	•				•	EC	•	HC 2 - #12, 1 - #12 GRD, 3/4" C
CU-1	COND. UNIT SUPPLY (ROOF)	72.2 A	1,3	•				•	EC	•	HC 3 - #2, 1 - #8 GRD, 1-1/4" C
CU-1	COND. UNIT RETURN (ROOF)	72.2 A	1,3	•				•	EC	•	HC 3 - #2, 1 - #8 GRD, 1-1/4" C
CU-2	COND. UNIT SUPPLY (ROOF)	72.2 A	1,3	•				•	EC	•	HC 3 - #2, 1 - #8 GRD, 1-1/4" C
CU-2	COND. UNIT RETURN (ROOF)	72.2 A	1,3	•				•	EC	•	HC 3 - #2, 1 - #8 GRD, 1-1/4" C
CU-3	COND. UNIT SUPPLY (ROOF)	72.2 A	1	•				•	EC	•	HC 3 - #2, 1 - #8 GRD, 1-1/4" C
CU-3	COND. UNIT RETURN (ROOF)	72.2 A	1	•				•	EC	•	HC 3 - #2, 1 - #8 GRD, 1-1/4" C
FC-1	VRF FAN COIL	(0.35)	2,3	•				•	EC	•	HC 2 - #12, 1 - #12 GRD, 3/4" C
FC-2	VRF FAN COIL	(0.35)	2	•				•	EC	•	HC 2 - #12, 1 - #12 GRD, 3/4" C
FC-3	VRF FAN COIL	(0.35)	2	•				•	EC	•	HC 2 - #12, 1 - #12 GRD, 3/4" C
FC-4	VRF FAN COIL	(0.35)	2	•				•	EC	•	HC 2 - #12, 1 - #12 GRD, 3/4" C
FC-5	VRF FAN COIL	(0.35)	2	•				•	EC	•	HC 2 - #12, 1 - #12 GRD, 3/4" C
EF-1	CT SCAN EXHAUST FAN (ROOF)	1/8	-	•				•	EC	•	HC 2 - #12, 1 - #12 GRD, 3/4" C
ERV-1	ENERGY RECOV. VENT. EXH.	1/2	-	•				•	EC	•	HC 3 - #12, 1 - #12 GRD, 3/4" C
ERV-1	ENERGY RECOV. VENT. SUPPLY	3/4	-	•				•	EC	•	HC 3 - #12, 1 - #12 GRD, 3/4" C

NOTES

1. UNIT CONSISTS OF TWO SEPARATE CONDENSING UNITS. EACH REQUIRES A SEPARATE ELECTRICAL CONNECTION.
2. PROVIDE POWER CONNECTION FOR VRF SYSTEM BRANCH SELECTION CONTROLLER FROM LOAD SIDE OF DISCONNECT SWITCH.
3. PROVIDE CONNECTION TO EMERGENCY POWER.

3023.00 ISSUED FOR BIDDING	01-31-2013	 CONTECH DESIGN, INCORPORATED Consulting Professional Engineers 519 Windsor Park Dr., Centerville, Ohio 45459 Phone: (937) 435-3722 Fax: (937) 435-4685 Email: engineers@contechdesign.com Engineer Project # 12014	 Revised By: <table><tr><td></td><td></td></tr><tr><td></td><td></td></tr><tr><td></td><td></td></tr><tr><td></td><td></td></tr><tr><td></td><td></td></tr></table>											Drawing Title ELECTRICAL NEW WORK POWER FLOOR PLANS Approved: Project Manager RANDI FIORINA Approved: Service Chief GARY ABREU	Project Title SITE PREP FOR CT SCANNER Building Number 335 Location 4100 WEST THIRD STREET DAYTON, OH 45428	Date 01-31-2013 Project No. 552-CSI-333 Drawing No. ES 3.1	 VA Department of Veterans Affairs



SCALE: $1/8" = 1 \text{ FOOT}$

VA FORM 08-6231, OCT 1978

Figure 1 illustrates the six stages (A-F) of the proposed algorithm for generating a 1D barcode from a binary image. Each stage shows a binary image on the left and its corresponding 1D barcode on the right. The barcode is a sequence of black and white bars of varying widths, representing the binary data. The stages are labeled A through F, and the final barcode is labeled 'F'.

Figure 1A: The binary image is a 1x1 grid of black pixels. The 1D barcode consists of a single black bar of width 1, followed by a white bar of width 1. The label 'three inches = one foot' is shown below the barcode.

Figure 1B: The binary image is a 1x2 grid of black pixels. The 1D barcode consists of a single black bar of width 2, followed by a white bar of width 2. The label 'one and one half inches = one foot' is shown below the barcode.

Figure 1C: The binary image is a 1x4 grid of black pixels. The 1D barcode consists of a single black bar of width 4, followed by a white bar of width 4. The label 'one inch = one foot' is shown below the barcode.

Figure 1D: The binary image is a 1x8 grid of black pixels. The 1D barcode consists of a single black bar of width 8, followed by a white bar of width 8. The label 'three quarters inch = one foot' is shown below the barcode.

Figure 1E: The binary image is a 1x16 grid of black pixels. The 1D barcode consists of a single black bar of width 16, followed by a white bar of width 16. The label 'one half inch = one foot' is shown below the barcode.

Figure 1F: The binary image is a 1x32 grid of black pixels. The 1D barcode consists of a single black bar of width 32, followed by a white bar of width 32. The label 'three eighths inch = one foot' is shown below the barcode.

A
—
B
—
C
—
D
—
E
—
F

1. FEEDERS FROM EXISTING PANELS TO NEW PANELS IN CT SCAN BUILDING, INCLUDING THREE TO PANELS AND ONE TO UPS ASSEMBLY.
2. ROUTE UPWARDS IN CHASE ADJACENT TO STAIRWAY. WHEREVER POSSIBLE, CO-LOCATE WITH ROUTES FOR NEW MRI BUILDING 335 FEEDS.

VA
Department of
Veterans Affairs

